



Flamco

EC Declaration of Conformity according to the Pressure Equipment Directive 97/23/EC of the European Parliament and the Council of 29 May 1997

Manufacturer
Flamco BV
Industriestraat 6
P.O.Box 115
2800 AC Gouda
the Netherlands

Notified Body
Lloyd's Register Nederland
Weena Zuid 170
3012 NC Rotterdam
the Netherlands

The following Conformity Assessment Modules are used for the below mentioned expansion vessels

Conformity Assessment Modules followed for Category I, II, III, IV	B and D
Marking Identification number on label	CE 0343
Maximum allowable working condition	see attached label
Medium	water/ gas
Fluid classification (Group) according to article 9	2
Applicable table PED appendix II	2
Harmonized standard applied	Based on (pr)EN 13831
Certificate nr. Module D (production quality assurance)	659935
Certificate Module B (EC type-examination) for Expansion vessels	

Flexcon

18, 25, 35, 50, 80 l	3 bar	PED/B/9003574
110, 140 l	10 bar	PED/B/4012350-1
110, 140, 200 l	6 bar	PED/B/4012350-2
300 l	6 bar	PED/B/4012350-3
200, 300 l	10 bar	PED/B/4012350-4
425, 600, 800, 1000 l	10 bar	PED/B/4012350-5
425, 600, 800, 1000 l	6 bar	PED/B/4012350-6

Flexcon Top

12, 18, 25, 35, 50, 80 l	6 bar	PED/B/9003574
110, 140 l	10 bar	PED/B/4012350-1
110, 140, 200 l	6 bar	PED/B/4012350-2
300 l	6 bar	PED/B/4012350-3
200, 300 l	10 bar	PED/B/4012350-4
425, 600, 800, 1000 l	10 bar	PED/B/4012350-5
425, 600 l	6 bar	PED/B/4012350-6

Flexcon C

18, 25, 35, 50, 80 l	3 bar	PED/B/9003574
110, 140, 200 l	6 bar	PED/B/4012350-2
300 l	6 bar	PED/B/4012350-3
425, 600, 800, 1000 l	6 bar	PED/B/4012350-6

Flexcon K

110, 140 l	10 bar	PED/B/4012350-1
200, 300 l	10 bar	PED/B/4012350-4
425, 600, 800, 1000 l	10 bar	PED/B/4012350-5

Flexcon Solar

8, 12, 18, 25, 35, 50, 80 l	8 bar	PED/B/9003574
110, 140 l	10 bar	PED/B/4012350-2

Flexcon Solar

200, 300 l	10 bar	PED/B/4012350-3
425, 600, 800, 1000 l	10 bar	PED/B/4012350-6

The manufacturer hereby declares that the expansion vessels are in compliance with the Pressure Equipment Directive 97/23/EC.

Managing director M. Verdegaal

Signature

